

## STATE OF TEXAS WELL REPORT for Tracking #97552

|                |  |               |                |
|----------------|--|---------------|----------------|
| Owner:         | Larry Johnson  | Owner Well #: | No Data        |
| Address:       | 1945 Country Club Est. Circle<br>San Angelo, TX 76904    | Grid #:       | 56-13-3        |
| Well Location: | 1.8 mi. N of 29 on FM 1222; .2 mi. W<br>in pasture<br>TX | Latitude:     | 30° 51' 15" N  |
|                |  | Longitude:    | 099° 23' 24" W |
| Well County:   | Mason  | Elevation:    | No Data        |

|               |          |               |          |
|---------------|----------|---------------|----------|
| Type of Work: | New Well | Proposed Use: | Domestic |
|---------------|----------|---------------|----------|

Drilling Start Date: 11/9/2006      Drilling End Date: 11/9/2006

|           | Diameter (in.) | Top Depth (ft.) | Bottom Depth (ft.) |
|-----------|----------------|-----------------|--------------------|
| Borehole: | 9              | 0               | 116                |
|           | 6.75           | 116             | 117                |
|           | 6              | 117             | 420                |

Drilling Method: Air Hammer

Borehole Completion: Open Hole

|                    | Top Depth (ft.) | Bottom Depth (ft.) | Description (number of sacks & material) |
|--------------------|-----------------|--------------------|--|
| Annular Seal Data: | 0               | 5                  | 1 Cement                                 |
|                    | 5               | 30                 | 4 Bentonite                              |

Seal Method: Grout

Sealed By: Driller

Distance to Property Line (ft.): No Data

Distance to Septic Field or other  
concentrated contamination (ft.): No Data

Distance to Septic Tank (ft.): No Data

Method of Verification: No Data

Surface Completion: Pitless Adapter Used

Water Level: 340 ft. below land surface on 2006-11-09      Measurement Method: Unknown

Packers: Rubber 30'

Type of Pump: Submersible      Pump Depth (ft.): 400

Well Tests: Jetted      Yield: 60+ GPM

Water Quality:

| Strata Depth (ft.) | Water Type        |
|--------------------|-------------------|
| 340 - 420          | good (590 ppmTDS) |

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which  
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **Virdell Drilling Inc.**  
**111 E. Grayson St.**  
**Llano, TX 78643**

Driller Name: **Taylor Virdell Jr.**

License Number: **1900**

Apprentice Name: **James Caleb Virdell**

Apprentice Number: **3254**

Comments: **No Data**

Lithology:  
DESCRIPTION & COLOR OF FORMATION MATERIAL

Casing:  
BLANK PIPE & WELL SCREEN DATA

| Top (ft.) | Bottom (ft.) | Description                              |
|-----------|--------------|--|
| 0         | 1            | Topsoil                                  |
| 1         | 50           | Brown Clay & Limestone                   |
| 50        | 110          | Gray Shale & Limestone<br>w/Sand Streaks |
| 110       | 210          | Gray Sandy Limestone (Cap<br>Mt.)        |
| 210       | 375          | Red Sandstone (Hickory)                  |
| 375       | 420          | Gray Sandstone                           |

| Dia. (in.)  | New/Used | Type       | Setting From/To (ft.) |
|-------------|----------|------------|-----------------------|
| 6" N PVC +2 | -        | 117 sch 40 |                       |

#### IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

**Texas Department of Licensing and Regulation**  
**P.O. Box 12157**  
**Austin, TX 78711**  
**(512) 334-5540**